


UGAM CHEMICALS

COMPANY	: AQUAPHARM CHEMICALS PVT. LTD. MAHAD.
PROBLEM REPORTED	: FIRE HAZARD WAS SEEN IN CHEMICAL STORAGE ROOM AND NEEDED TO BE PROTECTED WITH FIRE RETARDANT MATERIAL.
PROPOSED SOLUTION	: UGAMCOAT 141098 EP FOR STRUCTURAL STEEL & UGAMCOAT 07022007 WALLS FOR CHEMICAL STORING ROOM.
ACTION TAKEN	: ALL WALLS IN THOSE AREAS WERE COATED WITH UGAMCOAT 07022007 & STEEL STRUCTURE WAS COATED WITH UGAMCOAT 141098 FOR SAFETY PURPOSE.
RESULTS ACHIEVED	: 1 Hours Fire Rating achieved.



**30, ADITYA RESIDENCY, MITRAMANDAL CHOWK, 498, PARVATI, PUNE,
MAHARASHTRA, INDIA, TEL- 08669922233 / 08669922244.**

Fax- 020 24434075, e-mail- ugamchem@hotmail.com